

SC

TYPE 1 ELEVATION CERTIFICATE

THIS CERTIFICATE IS TO BE COMPLETED BY A REGISTERED ARCHITECT, LAND SURVEYOR OR CIVIL ENGINEER, AND RETURNED TO THE FLOODPLAIN MANAGEMENT SECTION OF PIMA COUNTY DEPARTMENT OF TRANSPORTATION AND FLOOD CONTROL DISTRICT.

THIS CERTIFICATE IS TO BE RETURNED TO PIMA COUNTY WITHIN 6 MONTHS AFTER THE MANUFACTURED HOME IS PLACED. FAILURE TO RETURN THIS CERTIFICATE IS A VIOLATION OF THE FLOODPLAIN MANAGEMENT ORDINANCE AND WILL RESULT IN A HOLD BEING PLACED ON ALL FUTURE BUILDING PERMITS FOR THIS OR ANY ADJACENT PROPERTY UNDER THE SAME OWNERSHIP.

See above

APR 1990
FLOOD
PLAIN
MANAGEMENT

BUILDING OWNERS NAME FRANK CHAVEZ

PROPERTY OWNERS NAME (IF DIFFERENT) _____

ADDRESS 7551 W. LOS REALES

LEGAL DESCRIPTION W2 NW4 NE4 NW4 S21-T15-R12

PHONE NO. 746-9226

BASIS OF REQUIREMENT FIRM PANEL 2800 1986

BY PERMIT OFFICIAL

THE PROPOSED MANUFACTURED HOME IS TO HAVE A MINIMUM ELEVATION DIFFERENCE OF 2 FEET BETWEEN THE LOWEST STRUCTURAL FRAME MEMBER AND THE HIGHEST ADJACENT GRADE. IF THE HOME IS TO BE PLACED ON A FILL PAD, THE FILL PAD MUST BE BUILT UP NA FEET ABOVE THE HIGHEST ADJACENT GRADE AND ARMORED.

BY REGISTRANT

THE BOTTOM OF THE LOWEST STRUCTURAL FRAME MEMBER IS _____ FEET ABOVE THE HIGHEST ADJACENT GRADE

East end of wide flange beam substructure is 2.0 feet above ground.
West end is 1.5 feet above ground. Average at midpoint is 1.75 feet.

NAME Larry Dadisman RLS

COMPANY NAME Kino Engineers and Surveyors

ADDRESS 2822 N. Fontana Ave., Tucson, Ariz. 85705

PHONE NO. 882 7118



OK \equiv 4-4-90

(Seal)

PERMIT NO. 89-270

ISSUE DATE 6-8-89

RECALL DATE 12-8-89

003