

SC

TYPE 1 ELEVATION CERTIFICATE

THIS CERTIFICATE IS TO BE COMPLETED BY A REGISTERED ARCHITECT, LAND SURVEYOR OR CIVIL ENGINEER, AND RETURNED TO THE FLOODPLAIN MANAGEMENT SECTION OF PIMA COUNTY DEPARTMENT OF TRANSPORTATION AND FLOOD CONTROL DISTRICT.

THIS CERTIFICATE IS TO BE RETURNED TO PIMA COUNTY WITHIN 6 MONTHS AFTER THE MANUFACTURED HOME IS PLACED. FAILURE TO RETURN THIS CERTIFICATE IS A VIOLATION OF THE FLOODPLAIN MANAGEMENT ORDINANCE AND WILL RESULT IN A HOLD BEING PLACED ON ALL FUTURE BUILDING PERMITS FOR THIS OR ANY ADJACENT PROPERTY UNDER THE SAME OWNERSHIP.

JAN 21 1990  
FLOOD  
MANAGEMENT

BUILDING OWNERS NAME SANDRA FLEMING *SF*

PROPERTY OWNERS NAME (IF DIFFERENT) \_\_\_\_\_

ADDRESS 8170 W. BOPP ROAD

LEGAL DESCRIPTION W356 E1270 N250 S280 SW4 SE4 S29-T14-R12

PHONE NO. (HOME) 578-1423 (WORK) 578-0341

BASIS OF REQUIREMENT SHEET FLOW PORTION OF LOT

BY PERMIT OFFICIAL

THE PROPOSED MANUFACTURED HOME IS TO HAVE A MINIMUM ELEVATION DIFFERENCE OF 1.5 FEET BETWEEN THE LOWEST STRUCTURAL FRAME MEMBER AND THE HIGHEST ADJACENT GRADE. IF THE HOME IS TO BE PLACED ON A FILL PAD, THE FILL PAD MUST BE BUILT UP NA FEET ABOVE THE HIGHEST ADJACENT GRADE AND ARMORED.

BY REGISTRANT

THE BOTTOM OF THE LOWEST STRUCTURAL FRAME MEMBER IS 2.0 FEET ABOVE THE HIGHEST ADJACENT GRADE

NAME

Don Pressnall

COMPANY NAME

PRESSNALL & ASSOCIATES

ADDRESS

4902 S. CACTUS WREN

PHONE NO.

883-8172



(Seal)

OK  
E 1-18-90

PERMIT NO. 84-359

ISSUE DATE 7-20-89

RECALL DATE 1-20-90

001