

SC

TYPE 1 ELEVATION CERTIFICATE

THIS CERTIFICATE IS TO BE COMPLETED BY A REGISTERED ARCHITECT, LAND SURVEYOR OR CIVIL ENGINEER, AND RETURNED TO THE FLOODPLAIN MANAGEMENT SECTION OF PIMA COUNTY DEPARTMENT OF TRANSPORTATION AND FLOOD CONTROL DISTRICT.

THIS CERTIFICATE IS TO BE RETURNED TO PIMA COUNTY WITHIN 6 MONTHS AFTER THE MANUFACTURED HOME IS PLACED. FAILURE TO RETURN THIS CERTIFICATE IS A VIOLATION OF THE FLOODPLAIN MANAGEMENT ORDINANCE AND WILL RESULT IN A HOLD BEING PLACED ON ALL FUTURE BUILDING PERMITS FOR THIS OR ANY ADJACENT PROPERTY UNDER THE SAME OWNERSHIP.

BUILDING OWNERS NAME PERRY SKIDMORE **JDS**

PROPERTY OWNERS NAME (IF DIFFERENT) _____

ADDRESS 2112 W. SINDLE PLACE

LEGAL DESCRIPTION S2 E2 NE4 LOT 1 S4-T15-R13

PHONE NO. _____

BASIS OF REQUIREMENT FIRM ZONE A PANEL 2220

BY PERMIT OFFICIAL

THE PROPOSED MANUFACTURED HOME IS TO HAVE A MINIMUM ELEVATION DIFFERENCE OF 2 FEET BETWEEN THE LOWEST STRUCTURAL FRAME MEMBER AND THE HIGHEST ADJACENT GRADE. IF THE HOME IS TO BE PLACED ON A FILL PAD, THE FILL PAD MUST BE BUILT UP NA FEET ABOVE THE HIGHEST ADJACENT GRADE AND ARMORED.

BY REGISTRANT

THE BOTTOM OF THE LOWEST STRUCTURAL FRAME MEMBER IS 2.1 FEET ABOVE THE HIGHEST ADJACENT GRADE

OK
E
10-16-89

NAME ALAN W. SPETH
COMPANY NAME JONES & ASSOCIATES INC.
ADDRESS 2627 N. FIRST AVE. TCN 85719
PHONE NO. (602) 624-1551



(Seal)

PERMIT NO. 89-421

ISSUE DATE 8-15-89

RECALL DATE 2-15-89