

SC

TYPE 2 ELEVATION CERTIFICATE

THIS CERTIFICATE IS TO BE COMPLETED BY A REGISTERED LAND SURVEYOR AND RETURNED TO THE FLOODPLAIN MANAGEMENT SECTION OF PIMA COUNTY DEPARTMENT OF TRANSPORTATION AND FLOOD CONTROL DISTRICT.

THIS CERTIFICATE IS TO BE RETURNED TO PIMA COUNTY PRIOR TO POURING THE FLOOR SLAB. FAILURE TO RETURN THIS CERTIFICATE IS A VIOLATION OF THE FLOODPLAIN MANAGEMENT ORDINANCE AND WILL RESULT IN A HOLD BEING PLACED ON ALL FUTURE BUILDING PERMITS FOR THIS OR ANY ADJACENT PROPERTY UNDER THE SAME OWNERSHIP.

BUILDING OWNERS NAME RENE MUHLBERG

PROPERTY OWNERS NAME (IF DIFFERENT) _____

ADDRESS 4902 N. OLD WEST RD TUCSON AZ 85743
1136 W. 12TH STREET TEMPE, ARIZONA 85281

LEGAL DESCRIPTION LOT 29 OLD WEST RANCHETTES BOOK 22 PAGE 98

PHONE NO. 1-921-3085 /- 682 8261

BASIS OF REQUIREMENT SHEET FLOW AREA

BY PERMIT OFFICIAL

THE PROPOSED HOME IS TO HAVE A MINIMUM ELEVATION DIFFERENCE OF 1½ FEET BETWEEN THE LOWEST FINISHED FLOOR ELEVATION AND THE HIGHEST ADJACENT GRADE. IF THE HOME IS TO BE PLACED ON A FILL PAD, THE FILL PAD MUST BE BUILT UP ½ FEET ABOVE THE HIGHEST ADJACENT GRADE AND ARMORED.

BY REGISTRANT OR
PIMA COUNTY
BUILDING INSPECTOR

THE LOWEST FINISHED FLOOR ELEVATION IS 1½' FEET ABOVE
THE HIGHEST ADJACENT GRADE.

NAME

Don M. J. Selby G-17

COMPANY NAME

P.C. BLDG CORP

ADDRESS

PHONE NO.

(Seal)

PERMIT NO. 89-664

ISSUE DATE 12/5/89

RECALL DATE 6/5/89

Approved 9/29/90