

FPUP # 94-404E

DSD # N/A

# ELEVATION CERTIFICATE

Important: Follow the instructions on pages 1-9.

Copy all pages of this Elevation Certificate and all attachments for (1) community official, (2) insurance agent/company, and (3) building owner.

SECTION A - PROPERTY INFORMATION				FOR INSURANCE COMPANY USE	
A1. Building Owner's Name Mark & Luzila Loomis				Policy Number:	
A2. Building Street Address (including Apt., Unit, Suite, and/or Bldg. No.) or P.O. Route and Box No. 12225 East Gold Dust Drive				Company NAIC Number:	
City Tucson		State Arizona		ZIP Code 85749	
A3. Property Description (Lot and Block Numbers, Tax Parcel Number, Legal Description, etc.) Taxcode: 205-50-0400 Township 14 Range 16 Section 05 49'ers Country Club Estates Lot 209					
A4. Building Use (e.g., Residential, Non-Residential, Addition, Accessory, etc.) Residential: Single Family Residence					
A5. Latitude/Longitude: Lat. 32.243949 Long. -110.730641 Horizontal Datum: <input type="checkbox"/> NAD 1927 <input checked="" type="checkbox"/> NAD 1983					
A6. Attach at least 2 photographs of the building if the Certificate is being used to obtain flood insurance. <small>Pima County Regional Flood Control District requires four (4) photographs.</small>					
A7. Building Diagram Number <u>LB</u>					
A8. For a building with a crawlspace or enclosure(s): a) Square footage of crawlspace or enclosure(s) <u>N/A</u> sq ft b) Number of permanent flood openings in the crawlspace or enclosure(s) within 1.0 foot above adjacent grade <u>N/A</u> c) Total net area of flood openings in A8.b <u>N/A</u> sq in d) Engineered flood openings? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
A9. For a building with an attached garage: a) Square footage of attached garage <u>665</u> sq ft b) Number of permanent flood openings in the attached garage within 1.0 foot above adjacent grade <u>N/A</u> c) Total net area of flood openings in A9.b <u>N/A</u> sq in d) Engineered flood openings? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
SECTION B - FLOOD INSURANCE RATE MAP (FIRM) INFORMATION					
B1. NFIP Community Name & Community Number Pima County / 040073			B2. County Name Pima County		B3. State Arizona
B4. Map/Panel Number 04019C2280	B5. Suffix B	B6. FIRM Index Date 02-15-1983	B7. FIRM Panel Effective/ Revised Date 02-15-1983	B8. Flood Zone(s) B	B9. Base Flood Elevation(s) (Zone AO, use Base Flood Depth) 2635.92
B10. Indicate the source of the Base Flood Elevation (BFE) data or base flood depth entered in Item B9: <input type="checkbox"/> FIS Profile <input checked="" type="checkbox"/> FIRM <input type="checkbox"/> Community Determined <input type="checkbox"/> Other/Source: _____					
B11. Indicate elevation datum used for BFE in Item B9: <input checked="" type="checkbox"/> NGVD 1929 <input type="checkbox"/> NAVD 1988 <input type="checkbox"/> Other/Source: Highest Adjacent Natural Grade (=100.0 ft)					
B12. Is the building located in a Coastal Barrier Resources System (CBRS) area or Otherwise Protected Area (OPA)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Designation Date: <u>N/A</u> <input type="checkbox"/> CBRS <input type="checkbox"/> OPA					



# ELEVATION CERTIFICATE

OMB No. 1660-0008  
Expiration Date: November 30, 2018

<b>IMPORTANT: In these spaces, copy the corresponding information from Section A.</b>			<b>FOR INSURANCE COMPANY USE</b>
Building Street Address (including Apt., Unit, Suite, and/or Bldg. No.) or P.O. Route and Box No. 12225 East Gold Dust Drive			Policy Number:
City Tucson	State Arizona	ZIP Code 85749	Company NAIC Number

## SECTION C – BUILDING ELEVATION INFORMATION (SURVEY REQUIRED)

C1. Building elevations are based on: ☐ Construction Drawings\* ☐ Building Under Construction\* ☒ Finished Construction

\*A new Elevation Certificate will be required when construction of the building is complete.

C2. Elevations – Zones A1–A30, AE, AH, A (with BFE), VE, V1–V30, V (with BFE), AR, AR/A, AR/AE, AR/A1–A30, AR/AH, AR/AO. Complete Items C2.a–h below according to the building diagram specified in Item A7. In Puerto Rico only, enter meters.

Benchmark Utilized: Geodetic PT INDEX CODE C07 Vertical Datum: NAVD 88

Indicate elevation datum used for the elevations in items a) through h) below.

☒ NGVD 1929 ☐ NAVD 1988 ☐ Other/Source: \_\_\_\_\_

Datum used for building elevations must be the same as that used for the BFE.

Check the measurement used.

- |   |                |  |
|---|----------------|--|
| a) Top of bottom floor (including basement, crawlspace, or enclosure floor)   | <u>2636.6</u>  | <input checked="" type="checkbox"/> feet <input type="checkbox"/> meters |
| b) Top of the next higher floor   | <u>2638.00</u> | <input checked="" type="checkbox"/> feet <input type="checkbox"/> meters |
| c) Bottom of the lowest horizontal structural member (V Zones only)   | <u>N/A</u>     | <input type="checkbox"/> feet <input type="checkbox"/> meters            |
| d) Attached garage (top of slab)  | <u>2636.00</u> | <input checked="" type="checkbox"/> feet <input type="checkbox"/> meters |
| e) Lowest elevation of machinery or equipment servicing the building<br>(Describe type of equipment and location in Comments) | <u>2633.6</u>  | <input checked="" type="checkbox"/> feet <input type="checkbox"/> meters |
| f) Lowest adjacent (finished) grade next to building (LAG)  | <u>2633.4</u>  | <input checked="" type="checkbox"/> feet <input type="checkbox"/> meters |
| g) Highest adjacent (finished) grade next to building (HAG)   | <u>2634.7</u>  | <input checked="" type="checkbox"/> feet <input type="checkbox"/> meters |
| h) Lowest adjacent grade at lowest elevation of deck or stairs, including structural support                                  | <u>N/A</u>     | <input type="checkbox"/> feet <input type="checkbox"/> meters            |

PCRFCD Note: Indicate lowest adjacent natural grade (LANG) in Section D.

PCRFCD Note: Indicate highest adjacent natural grade (HANG) in Section D.

## SECTION D – SURVEYOR, ENGINEER, OR ARCHITECT CERTIFICATION

This certification is to be signed and sealed by a land surveyor, engineer, or architect authorized by law to certify elevation information. I certify that the information on this Certificate represents my best efforts to interpret the data available. I understand that any false statement may be punishable by fine or imprisonment under 18 U.S. Code, Section 1001.

Were latitude and longitude in Section A provided by a licensed land surveyor? ☐ Yes ☒ No ☒ Check here if attachments.

Certifier's Name <u>EVERETT TRUEBLOOD</u>		License Number <u>RLS 25405</u>	
Title <u>OWNER</u>			
Company Name <u>EVERETT TRUEBLOOD LAND SURVEYING</u>			
Address <u>6884 W. HERMITAGE PL</u>			
City <u>TUCSON</u>	State <u>AZ</u>	ZIP Code <u>85743</u>	
Signature <u>[Signature]</u>	Date <u>8-22-17</u>	Telephone <u>520-888-2549</u>	
Ext. _____			

Copy all pages of this Elevation Certificate and all attachments for (1) community official, (2) insurance agent/company, and (3) building owner.

Comments (including type of equipment and location, per C2(e), if applicable)  
The lowest service equipment (C3.e) is the AC UNIT and the OTHER EQUIPMENT are above this elevation.  
Highest adjacent natural grade is 2633.3 Lowest adjacent natural grade is 2632  
For manufactured homes only: The elevation of the bottom of the lowest horizontal structural member is N/A  
For additions: The finished floor elevation of the original existing structure is N/A



*SOUTHSIDE  
8-16-2017*





WESTSIDE  
8-16-2017





EASTSIDE  
8-16-2017





NORTHSIDE  
8-16-2017



RECEIVED

AUG 28 2017

RFCD

Hi Francisco,

I am sending you a revised elevation cert for 12225 E Gold Dust Drive using NGVD 29 and the benchmark as shown on the information I originally sent. Also I am giving you elevations starting at the centerline of Gold Dust Drive and the wash being 0+00 and going 50 feet west for 200 feet so you can compare your maps to what I am finding. 0+00= 2629.7 0+50= 2629.2 1+00= 2628.6 1+50= 2628.1 and 2+00= 2628.1. Also the house to the south has a finish floor of 2634.3. Let me know it did not look right. I will be gone till next Friday but you can email me if you see something strange [etrueblood21@comcast.net](mailto:etrueblood21@comcast.net).

Everett Trueblood

Everett Trueblood Land Surveying